

Fire Application #313637 - KPP Bldg D Standpipe

[illegible]



CITY OF KIRKLAND



Fire Application #313637 - KPP Bldg D Standpipe

Project Contact

Company Name: McKinstry Co

Name: Jim Thomas

Email: permits@mckinstry.com

Address: 5005 3rd Ave S PO Box 24567
Seattle WA 98134

Phone #: (206) 763-4819

Project Type

Nonresidential

Activity Type

Alteration

Scope of Work

Underground Fire Service

Project Name: KPP Bldg D Standpipe

Description of Work: Remove existing fire pump, and reroute underground supply to feed new back flow, and wet system for bldg D. Connect wet system to existing dry standpipe w/check valve and new signage. Replace existing 3" Wet Riser w/4", and change Penthouse dry system to a Wet System.

Project Details

Structure Type

Primary Building

System Information

This is a modification or addition to an existing system